

## Manufacturer's Declaration for Sensors for Use in Hazardous Areas

**Product:** Differential pressure switch  
**Type:** DBK-2G3D  
**Installation in:** Zones 1, 2 and 22

**Manufacturer:** Schischek GmbH  
**Properties:** passive, potential-free  
**Associated apparatus:** EXL-IRU-1, ExBin-A, RedBin-A

The differential pressure switch was evaluated for installation and use in explosive atmospheres of zones 1, 2 and 22. Directive 2014/34/EU was used as base for the evaluation. Moreover, the standards EN 60079-0, EN 60079-11 and EN 60079-31 were applied. The differential pressure switch is simple apparatus in the meaning of EN 60079-11 sub-clause 5.7 and has to be operated via an intrinsically-safe circuit. Switching amplifier type EXL-IRU-1 with EC type examination number PTB 02 ATEX 2195 and Ex marking II (1) GD [EEx ia] IIC or products ExBin-A and RedBin-A that can directly be installed in zones 1 and 21 (ExBin-A) or zones 2 and 22 (RedBin-A) are suitable. The switching amplifier may only be installed and operated in non-hazardous atmospheres.

### Verification of intrinsic safety for simple electrical apparatus in conjunction with switching amplifier EXL-IRU-1

$U_o \leq U_i$	$13,5 \text{ V} \leq 15 \text{ V}$	OK	$C_o \geq C_i + C_{\text{cable}}$	$C_i = 0 \mu\text{F}$
$I_o \leq I_i$	$23 \text{ mA} \leq 50 \text{ mA}$	OK	$L_o \geq L_i + L_{\text{Cable}}$	$L_i = 0 \text{ mH}$
$P_o \leq P_i$	$76 \text{ mW} \leq 100 \text{ mW}$	OK	$C_{\text{Cable}}, L_{\text{Cable}}$ : refer to cable manufacturer's data	
$C_o, L_o$ : values according to gas group, refer to data sheet of EXL-IRU-1				

### Verification of intrinsic safety for simple electrical apparatus in conjunction with products ExBin-A and RedBin-A

$U_o \leq U_i$	$7,14 \text{ V} \leq 15 \text{ V}$	OK	$C_o \geq C_i + C_{\text{cable}}$	$C_i = 0 \mu\text{F}$
$I_o \leq I_i$	$8 \text{ mA} \leq 50 \text{ mA}$	OK	$L_o \geq L_i + L_{\text{Cable}}$	$L_i = 0 \text{ mH}$
$P_o \leq P_i$	$15 \text{ mW} \leq 100 \text{ mW}$	OK	$C_{\text{Cable}}, L_{\text{Cable}}$ : refer to cable manufacturer's data	
$C_o, L_o$ : values according to gas group, refer to data sheet of ExBin-A and RedBin-A				

Test	Result
IP protection	The equipment complies with min. IP65
Evaluation of metallic parts	Magnesium, titanium and zirconium content < 7,5%
Evaluation of plastics	Suitable for ambient operating temperature range of -30°C..+60°C
Electrostatics	No limitations for use in groups IIA and IIB, for use in group IIC the warning "Only wet cleaning" or similar applies
Fasteners	No particular conditions, not applicable
Grounding	Plastic enclosure, no grounding necessary/grounded via structural parts respectively
Cable entries	The cables have to be protected against mechanical and thermal damage, after installation IP65 has to be complied with
Temperature rise test	No temperature rise >5K measured in conjunction with switching amplifier of type EXL-IRU-1; sensors are, among others, suitable for -30°C to +60°C

### Final evaluation

The differential pressure switch of type DBK-2G3D is suitable for use in conjunction with Schischek's switching amplifier of type EXL-IRU-1 and products ExBin-A and RedBin-A in zones 1, 2 and 22. The information contained in the specification sheet/user manual has to be observed. Likewise, the warning statements referring to electrostatics have to be observed. After installation IP protection IP65 has to be guaranteed.



Langenzenn, May 06, 2016  
 Arno Butzke  
 Explosion protection representative